



DOMINION ENERGY SOUTH CAROLINA DISTRIBUTION LINE CLEARING

THREE PHASE LINE

SINGLE PHASE LINE

* For illustrative purposes.
Not to scale.

SAFEGUARD ZONE

SAFEGUARD ZONE

20' Min.

20' Min.

10' Min.

10' Min.

10' Min.

10' Min.

Vegetation cleared from guy wires and anchors.

NEUTRAL

4' Min.

NEUTRAL

4' Min.

Volunteer woody vegetation and vines will be cut, and/or treated with herbicide.

15'

15'

15'

15'

Service cleared for abrasion.

Plantings with mature heights >15' are subject to removal.

